



**NOTES:**

1. FOR LEGEND, ABBREVIATIONS, KEY PLAN, AND GENERAL NOTES, SEE DWG E-1.
2. FOR B2 LEVEL STROBE AND SPEAKER RISER DIAGRAM, SEE DWG E-4.
3. FOR B2 LEVEL STROBE, HORN AND SPEAKER CIRCUIT SCHEDULE, SEE DWG E-34.
4. REMOVAL OF THE EXISTING E.O.L. AND CONNECTION OF THE NEW WIRING TO THE EXISTING SPEAKER SHALL BE MADE BY CONTRACTOR IN THE PRESENCE AND UNDER THE DIRECT SUPERVISION OF THE ENGINEER.

Sheet 10 of 37

**THE PORT AUTHORITY**  
OF NEW YORK AND NEW JERSEY

*[Signature]*  
ENGINEERING PROGRAM MANAGER  
WORLD TRADE CENTER  
CHIEF ELECTRICAL ENGINEER

No. Date Revision

ENGINEERING DEPARTMENT

WORLD  
TRADE  
CENTER

ELECTRICAL

Title  
FIRE ALARM SYSTEM  
PHASE III  
5 WTC MER'S, EMR'S  
AND SUBSTATIONS

B2 LEVEL EMR  
STROBE AND SPEAKER  
PLAN

This drawing subject to conditions in Contract. All inventions, ideas, designs and methods herein are reserved to Port Authority and may not be used without its written consent.

FELDMAN ROYMAN  
Designed by Drawn by Checked by

5-17-99  
Date

WTC-861.571 E-9  
Contract Number Drawing No.

I HEREBY CERTIFY THAT THIS IS A TRUE AND CORRECT COPY OF ONE OF THE CONTRACT DRAWINGS CONSTITUTING A PART OF CONTRACT NO. WTC-861.571 IN THE FORM IN WHICH SAID DRAWINGS EXISTED AT THE TIME THE SAID CONTRACT WAS EXECUTED BY THE PARTIES.

DATE 12/17/99 CONTRACT ENGR/ARCH.  
DATE 1/16/00 ENGINEERING PROGRAM MGR.

